

# 2024 Annual Drinking Water Quality Report

## of the Town of Grand Ridge

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is ground water from four (4) wells. The wells draw from the Floridan Aquifer. Because of the excellent quality of our water, the only treatment required is chlorine for disinfection purposes.

If you have any questions about this report or concerning your water utility, please contact Justin Branch at 850-592-4621 or P.O. Drawer 180, Grand Ridge, FL, 32442. We encourage our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Thursday of each month at 6:00 PM at the Grand Ridge Town Hall.

The Town of Grand Ridge routinely monitors for contaminants in your drinking water according to Federal and State laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2024. Data obtained before January 1, 2024, and presented in this report are from the most recent testing done in accordance with the laws, rules, and regulations.

In the table below, you may find unfamiliar terms and abbreviations. To help you better understand these terms, we've provided the following definitions:

**Maximum Contaminant Level or MCL:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal or MCLG:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Maximum residual disinfectant level or MRDL:** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum residual disinfectant level goal or MRDLG:** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**"ND"** means not detected and indicates that the substance was not found by laboratory analysis.

**Parts per billion (ppb) or Micrograms per liter (µg/l):** one part by weight of analyte to 1 billion parts by weight of the water sample.

**Parts per million (ppm) or Milligrams per liter (mg/l):** one part by weight of analyte to 1 million parts by weight of the water sample.

**Picocurie per liter (pCi/L):** measure of the radioactivity in water.

## 2024 TEST RESULTS TABLE

Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination	
	Inorganic Contaminants							
Fluoride (ppm)	Oct 24	N	0.12	0.1 - 0.12	4	4.0	Erosion of natural deposits; discharge from fertilizer and aluminum factories. Water additive which promotes strong teeth when at the optimum level of 0.7 ppm	
Barium (ppm)	Oct 24	N	0.009	0.004 – 0.009	2	2	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits	
Sodium (ppm)	Oct 24	N	7.4	2.1 – 7.4	N/A	160	Saltwater intrusion, leaching from soil	
Nitrate (as Nitrogen) (ppm)	Oct 24	N	0.87	ND-0.87	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits	
Chromium (ppb)	Oct 24	N	2.4	ND – 2.4	100	100	Discharge from steel and pulp mills; erosion of natural deposits	
	Radioactive Contaminants							
Alpha emitters (pCi/L)	Jan 19 Oct 24	N	1.2	ND – 1.2	0	15	Erosion of natural deposits	
Radium 226 + 228 or combined radium (pCi/L)	May 21	N	0.3	ND - 0.3	0	5	Erosion of natural deposits	
	Stage 2 Disinfectant/Disinfection By-Product (D/DBP)							
Disinfectant or Contaminant and Unit of Measurement		Dates of sampling (mo./yr.)	MCL or MRDL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Chlorine (ppm) (Stage 1)		Oct 24	N	0.8	0.5 – 1.76	MRDLG = 4	MRDL = 4.0	Water additive used to control microbes
Total Trihalomethanes (TTHM) (ppb)		Oct 24	N	1.4	N/A	N/A	80	By-product of drinking water disinfection
	Lead and Copper (Tap Water)							
Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	AL Exceed ed Y/N	90th Percentile Result	No. of sampling sites exceeding the AL	Range of Tap Sample Results	MCLG	AL (Action Level)	Likely Source of Contamination
Copper (tap water) (ppm)	Jan - Sept 23	N	0.063	0 of 10	0.018 – 0.07	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (tap water) (ppb)	Jan - Sept 23	N	2.1	0 of 10	ND – 7.7	0	15	Corrosion of household plumbing systems and service lines connecting buildings to water mains; erosion of natural deposits

*The Town of Grand Ridge does not have lead in the drinking water above the acceptable limits. Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Grand Ridge is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Justin Branch, The Town of Grand Ridge, at 850-592-4621 or P.O. Drawer 180, Grand Ridge, FL, 32442.*

Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at: <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

In 2024, the Department of Environmental Protection performed a Source Water Assessment on our system. The assessment was conducted to provide information about any potential sources of contamination in the vicinity of our wells. There are 5 sources of potential contamination with low to high susceptibility levels. The assessment results are available on the FDEP Source Water Assessment and Protection Program website at [www.dep.state.fl.us/swapp](http://www.dep.state.fl.us/swapp) or they can be obtained from the Grand Ridge Town Hall at (850)-592-4621.

**Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).**

In our continuing efforts to maintain a safe and dependable water supply, it may be necessary to make improvements in your water system. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. The Federal Environmental Protection Agency has revised the Lead and Copper rule for all public drinking water systems. They have mandated that drinking water systems produce an inventory list of all service line material. The service line is the piping that extends from our water main to the customer's meter as well as the piping that extends from the meter to the customer's home. The Town of Grand Ridge has prepared this inventory in accordance with federal regulations. To view this service line inventory, contact Justin Branch,

*Town of Grand Ridge or visit:*

[https://depedms.dep.state.fl.us:443/Oculus/servlet/shell?command=getEntity&\[guid=32.1695591.1\]&\[profile=Sampling\]](https://depedms.dep.state.fl.us:443/Oculus/servlet/shell?command=getEntity&[guid=32.1695591.1]&[profile=Sampling])

*Corrosion of pipes, plumbing fittings and fixtures may cause metals, including lead and copper, to enter drinking water. To assess corrosion of lead and copper, The Town of Grand Ridge conducts tap sampling for lead and copper at selected sites triennially. The most recent set of lead and copper tap sampling is available for review.*

*To view the lead and copper tap sampling data, contact Justin Branch or visit:*

[https://depedms.dep.state.fl.us:443/Oculus/servlet/shell?command=getEntity&\[guid=32.1588350.1\]&\[profile=Sampling\]](https://depedms.dep.state.fl.us:443/Oculus/servlet/shell?command=getEntity&[guid=32.1588350.1]&[profile=Sampling])

*We at the Town of Grand Ridge would like you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. If you have any questions or concerns about the information provided, please feel free to call any of the numbers listed above.*