

Lead Service Line Replacement Plan (LSLRP)

All water systems with one or more lead, galvanized requiring replacement, or lead status unknown service lines in their distribution system must, by October 16, 2024, submit a lead service line replacement plan, LSLRP, to the State in accordance with 40 CFR § 141.90(e). Based on the LCRR requirements, the plan must include the information described below, as applicable.

- A strategy for determining the composition of lead status unknown service lines in its inventory.
- A procedure for conducting full lead service line replacement.
- A strategy for informing customers before a full or partial lead service line replacement.
- For systems that serve more than 10,000 persons, a lead service line replacement goal rate is recommended by the system in the event of a lead trigger level exceedance.
- A procedure for customers to flush service lines and premise plumbing of particulate lead.
- A lead service line replacement prioritization strategy based on factors including but not limited to the targeting of known lead service lines, lead service line replacement for disadvantaged consumers and populations most sensitive to the effects of lead.
- A funding strategy for conducting lead service line replacements which considers ways to accommodate customers that are unable to pay to replace the portion they own.